



JAMAICA PUBLIC SERVICE CO. LTD.

REQUEST FOR PROPOSALS

The Supply of Automatic Circuit Reclosure

RFP # 898472

Addendum # 2

4.0 Submission of Bids and Selection Criteria

All responses must be in English Language. Your bid response must be presented in two (2) separate Files, namely Financial/Costing and Technical Specifications. The deadline for submission of bids is **11:59pm on January 13, 2022**.

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	December 6, 2021	JPS
Bidder submits questions on RFP	December 13, 2021	Bidder
Final date to respond to all queries	December 16, 2021	JPS
Bidder Provide Intension to Bid	December 20, 2021	Bidder
Completion of RFP and deadline for Upload of bids to JPS	January 13, 2022	Bidder
Bid Opening	January 14, 2022	JPS

Question and Answers

- 4.2 - Industry standard for this voltage class is 125kV BIL. Will 125kV BIL be accepted with a 955mm L-G creepage?
Answer: We specify 150kV BIL
- 4.4.2 - This section includes multi-ratio CTs with substation accuracy. Will CTs that match standard pole-mount IEC/IEEE recloser standards that contain appropriate dual ratio and properly rated CTs that do not saturate through the full fault rating of the recloser be accepted as an alternative?
Answer: Yes
- 4.6 - DC Control input voltage would be indicative of a substation application. Will 120-240 VAC control input voltage be accepted?
Answer: Yes. With battery backup.
- 5 - Is there a preferred relay supplier?
Answer: NOJA POWER RC15